

### **Clarification Request**

**Request from:** BTL Manager ([btl-manager@bacnetinternational.org](mailto:btl-manager@bacnetinternational.org))

**Reference:** "BTL Specified Tests 3.0.final", "ASHRAE 135 2004"

**Background:**

In several of the Acknowledge Alarm Service tests in the BTL Specified Tests document, there appears to be a requirement that when the Ack\_Required property is set to TRUE that the Notify\_Type property must be set to ALARM.

The ASHRAE 135 2004 does not have this restriction.

**Question:**

Is this an implied requirement or should the tests be modified to have EVENT | ALARM for their Notify\_Type?

**Response:**

Yes. The BTL will modify the tests that are affected.