

### Clarification Request

**Request from:** "Manoj Kumar Farkya" < >

**References:** 135.1-2009 tests 9.22.2.3 and 9.23.2.6

**Stage:** ☒Request, ☐Listed, ☐Analysis, ☐Resolved

**Actions necessitated:** ☐Checklist/Test Plan change, ☒BTL Specified Tests change,  
☐SSPC Interpretation required, ☐Implementation Guidelines change,

**Date of BTL-WG Response:** \_\_\_\_\_  
☐All actions necessitated have been completed

#### Background:

As per test plan 9.0 for test "135.1-2009 - 9.22.2.3 - Writing with a Property Value Having the Wrong Datatype" for protocol revision '6' Error Code "Invalid Datatype" is only expected.

While for test "135.1-2009i-10 - 9.23.2.6 - Writing with a Property Value Having the Wrong Datatype" several Reject errors are also accepted. Same Errors should be updated for test 9.22.2.3 also.

#### Question:

Can same error checking code be implemented for both WP as for WPM services?

#### Response:

For this pair of tests, 9.22.2.3 accepts the same set of error responses as 9.23.2.6.