

### **Clarification Request**

**Request from:** PolarSoft

**Reference:** "BTL Specified Tests-3.0.final", "ASHRAE 135.1-2003, section 9.8.6, pg 1998"

**Background:**

The GetEventInformation test "9.8.6 Chaining Test" requires that test be executed using a 50 octet APDU but a GetEventInformation response will not fit within 50 octets when timestamps of the BACnetDateTime form are used.

In such cases should the test be executed with a 128 octet APDU instead?

**Response:**

The BTL working group agrees that the TD shall be configured with an APDU size of at least 128 and the IUT shall be configured to contain enough events to cause the chaining action. The BTL working group will create a modified test for the test package and submit test changes to the SSPC.