

### **Clarification Request**

**Request from:** BTL Manager (btl-manager@bacnetinternational.org)

**References:** "BTL Checklist-3.0.final", "BTL Test Plan-3.0.final", "ASHRAE 135-2004"

**Stage:** ☒Request, ☒Listed, ☒Analysis, ☒Resolved

#### **Background / Proposed Solution:**

The BTL Test Plan and Checklist seem to imply that if the IUT supports BBMD functionality that the IUT must also support the Write-Broadcast-Distribution-Table message by requiring tests that use this service.

Section J.4.4 BBMD Configuration - in ASHRAE 135-2004, states: "The table may be supplied by local means or by means of the BVLL Write-Broadcast-Distribution-Table message".

I did not find anything in the BTL Implementer's Guide which highlights this requirement.

#### **Question:**

Is it the intent of the BTL to require that a BBMD support the Write-Broadcast-Distribution-Table message?

#### **Response:**

Yes. See J.4.5 BBMD Operation, paragraph 1.