

Clarification Request

Request from: BTL Manager (btl-manager@bacnetinternational.org)

Reference: "BTL Test Plan-3.0.final", "BTL Specified Tests-3.0.Final"

Background:

The test listed for the COV-B infinite Lifetime support is incorrect in the Test Plan document.

Proposed Solution:

The proposed solution is to modify the Test Plan document so that any of the standard 8.2 section tests can be run. The Test Conditionality will state that a Lifetime = 0 shall be used.

We also propose the addition of a new test that will verify that a SubscribeCOV in which the Lifetime parameter is not specified, is correctly interpreted as an infinite subscription.

Question:

Is this proposed solution acceptable?

Response:

Yes.