

## Errata

BTL Test Package 15.0 (plus any published addenda (applied to create 15.1))

3/26/2018

This document lists all known *errata* to BTL Test Package 15.0 as of the above date. Each entry is first cited by clause, then page number, except where an erratum covers more than one clause.

- 1) Change NM-RC-B name from Router Control to Router Configuration in both the Checklist and the Test Plan documents.
- 2) In BTL Test Plan, section 8.1.3 Initiates Unicast Who-Is Service Request with no Range Parameters, change the referenced test from 135.1-2013 8.34.1 to 8.34.4 - Who-Is Request with no Device Instance Range.
- 3) In BTL Specified Tests, Change Configuration Requirements for the following listed 4 tests to remove the words "by more than COV\_Increment". 8.2.3, 8.2.4, 8.2.5, 8.2.6
- 4) In BTL Specified Tests and BTL Test Plan, renumber duplicate instances of test 7.2.X7 and 7.2.X8 to be unique. (See addenda 15a-4 and a-5) (Horst says watch duplicates they are not identical. need to figure out which is the latest version and use that one).
- 5) In BTL Checklist and BTL Test Plan, update the BIBB names to match 135-2016 publication (i.e. fully spelled out in all places). See below for some that will change. Verify ALL before release.

K.1.11 BIBB - Data Sharing-Change Of Value-A (DS-COV-A)

K.1.12 BIBB - Data Sharing-Change Of Value-B (DS-COV-B)

K.1.13 BIBB - Data Sharing-Change Of Value Property-A (DS-COVP-A)

K.1.14 BIBB - Data Sharing-Change Of Value Property-B (DS-COVP-B)

K.1.15 BIBB - Data Sharing-Change Of Value-Unsubscribed-A (DS-COVU-A)

K.1.16 BIBB - Data Sharing-Change Of Value-Unsubscribed-B (DS-COVU-B)

K.2.4 BIBB - Alarm and Event Management-Acknowledge-A (AE-ACK-A)

K.2.5 BIBB - Alarm and Event Management-Acknowledge-B (AE-ACK-B)

- 6) In BTL Specified Tests and BTL Test Plan: Swap test references for tests: 135.1-2013 - 7.3.2.23.11.3 Externally Written Datatypes Test, non-NULL values and Tests 135.1-2013 - 7.3.2.23.11.4 Externally Written Datatypes Test, NULL values and Priority\_Arrays.
- 7) In BTL Checklist (Addenda b), fix up the footnotes as appropriate before applying to Test Package version of checklist.
- 8) In BTL Checklist (Addenda b), fix up the footnote in AE-N-I-B and AE-N-E-B to end in 'algorithm' instead of 'object'.
- 9) In BTL Specified Tests, changed test 10.2.2.7.2 Unknown Network Layer Message Type DNET should be (any value) per clarification noted in ao-3. wID0341.
- 10) In BTL Specified Tests, change test 8.5.X1.1 CHANGE\_OF\_RELIABILITY with No Fault Algorithm step 4 such that the 'Event Values' are (T,T,?,?) instead of (?,T,?,?) and in Step 8 the 'Event Values' are (F,F,?,?) instead of (?,F,?,?). (per BTLWG-364)
- 11) In BTL Specified Tests, change test 8.5.X1.3 CHANGE\_OF\_RELIABILITY with the FAULT\_EXTENDED Algorithm, step 8 such that the 'Event Values' are (F,F,?,?) instead of (?,F,?,?). (per BTLWG-364)
- 12) In BTL Specified Tests, change test 8.5.X1.8 CHANGE\_OF\_RELIABILITY of Event Enrollment Object, Monitored Object Fault such that step 4 'Event Values' M1 Status\_Flags are (T,T,?,?) instead of (?,T,?,?). (per BTLWG-364)
- 13) In BTL Specified Tests, change test 8.5.X1.10 After FAULT-to-NORMAL, Re-Notification of OFFNORMAL, such that step 7 'Event Values' flags are (T,T,?,?) instead of (?,T,?,?). (per BTLWG-364)
- 14) In BTL Specified Tests, change test 8.X1.11 CHANGE\_OF\_RELIABILITY with First Stage Object Fault such that step 4 'Event Values' flags are (T,T,?,?) instead of (?,T,?,?) and step 8 'Event Values' are (F,F,?,?) instead of (?,F,?,?). (per BTLWG-364)