## **Clarification Request**

## References: BTL - 7.3.2.X56.1

Date of BTL-WG Response: June 24, 2021

Background: Specified Tests 18.1. Final

BTL - 7.3.2.X56.1 - Authentication_Status and Access_Event Test		
	Test	Must be executed. This test shall be skipped if Out_Of_Service
	Conditionality	is not writeable.
	Test Directives	
	<b>Testing Hints</b>	

Reason for Change: No test exists for this functionality. This test is not in any SSPC proposal.

Purpose: This test case verifies the authentication and authorization process are disabled when Out\_Of\_Service of the Access Point object is TRUE. It also verifies the interrelationship between the Out\_Of\_Service, Authentication\_Status,Access\_Event and Access\_Event\_Time properties.

Test Concept: Write TRUE to the Out\_Of\_Service property and verify that the authorization and authentication functions are disabled. Write FALSE to the Out\_Of\_Service property and verify that they are enabled.

Configuration Requirements: See 7.3.2.X56

Test Steps:

- 1. VERIFY Authentication\_Status = READY
- 2. IF (Out\_Of\_Service is writable) THEN WRITE Out\_Of\_Service = TRUE ELSE MAKE (Out Of Service TRUE)
- MAKE (Out\_Of\_Service TRUE)
- 3. VERIFY Authentication\_Status = DISABLED
- 4. VERIFY Access\_Event = OUT\_OF\_SERVICE
- 5. VERIFY Access\_Event\_Time = (the time Out\_Of\_Service was set to TRUE)
- 6. IF (Out\_Of\_Service is writable) THEN WRITE Out\_Of\_Service = FALSE ELSE
- MAKE (Out\_Of\_Service FALSE)
- 7. VERIFY Authentication\_Status = READY
- 8. VERIFY Access\_Event = OUT\_OF\_SERVICE\_RELINQUISHED
- 9. VERIFY Access\_Event\_Time = (the time Out\_Of\_Service was set to FALSE)

## Problem:

The above listed testcase is the part of the Base Requirement section of Access Point Object.

Lab received a device in which the Out\_Of\_Service property is not writable also there is no method to do so. Vendor states: "Our design was to not allow Out\_Of\_Service in the

ACP to make it simpler for the user as there are other ways to accomplish stopping Authentication and Out\_Of\_Service is not required to be writeable as per specification".

## Question:

1) Shall we update the test Conditionality, in TestPlan to skip this testcase if Out\_Of\_Service property is not writable OR cannot be made to TRUE.

Response: Yes.