

### Clarification Request

**References:** BTL Specified Tests-12.0.final test 9.20.1.8

**Date of BTL-WG Response:** May 14, 2015

☒ All actions necessitated have been completed

**Background:**

I checked again the BACnet standard and BTL test case and think whether it is a problem is debatable. For AV points in our product, we cannot put a empty list as optional properties based on below 2 reasons:

1. For each AV point, we support "Description" property, which should be included in "optional" list
2. For some AV points, "Priority Array" and "Relinquish Default" is supported

I think for all AV points in one product, it should supported consistent "optional" list. Since for AV1~AV12, we really does not support "Priority Array" and "Relinquish Default", we should reply with unknown-property.

**Question:**

Should the test be modified to allow 'Error Class': property 'Error Code':  
UNKNOWN\_PROPERTY in ReadPropertyMultiple for OPTIONAL responses?

**Response:**

**No**