

Clarification Request

References: BTL Test Plan-16.1

Date of BTL-WG Response: April 30, 2020

All Actions Necessitated have been Completed

Background: Functionality Checklist has below claimed for Alarm and Event Management - Alarm Summary View - A

Alarm and Event Management - Alarm Summary View - A		
X	R	Base Requirements
X	R	Supports initiation of GetEventInformation service
X	R	Supports initiation of GetAlarmSummary service
X	R	Supports initiation of GetEnrollmentSummary service
	O	Generates GetEnrollmentSummary requests with an Enrollment filter
	O	Generates GetEnrollmentSummary requests with an Event State filter
	O	Generates GetEnrollmentSummary requests with an Event Type filter
	O	Generates GetEnrollmentSummary requests with a Priority filter
	O	Generates GetEnrollmentSummary requests with a Notification Class filter
	O	Generates GetEnrollmentSummary requests with multiple filters

Where supports of initiation of GetEventInformation service, supports initiation of GetAlarmSummary service and Supports initiation of GetEnrollmentSummary service are required claims to support the AE-AS-A BIBB

Problem:

As per the section K.2.18 BIBB - Alarm and Event Management-Alarm Summary View-A (AE-AS-A) of BACnet standard only initiation of GetEventInformation and GetAlarmSummary services are mandatory services to support the AE-AS-A which conflicts with the claims mentioned in the Functionality Checklist.

Question:

1. Does the conformance code of “ Supports initiation of GetEnrollmentSummary should change from R to O ?

Response: Yes.