

Clarification Request

References: “e.g” testplan 18 and 20 section 4.20.1 covp-B base requirements

Date of BTL-WG Response: February 10, 2022

Background: “e.g” Specified Tests 14.0.Final or 135.1-2013 Test-Number

Base requirements for COVP-B have test 9.11.1.9 with conditionality “must be executed”.

Problem:

Test 9.11.1.9 does only apply for properties with numeric datatype. If the IUT does not have any property with numeric datatype, that supports COVP the test can not be executed.

Question:

Should the conditionality be changed to:

“must be executed if the IUT can be made to contain a property of numeric datatype with support for COVP”?

RESPONSE:

YES