

Clarification Request

References: BTL Test Plan-5.0.final section 4.2.9

Background / Proposed Solution:

BTL Test Plan section 4.2.9 has a Testing Hints that reads:

There are no standard properties that are Octet Strings so this will have to be executed against a proprietary property.

But Active_COV_Subscriptions is a standard property that contains an Octet String when it is not an empty list.

Question:

Should that Hint be stricken or revised?

Response:

No.