

## **Clarification Request**

**References:** 9.2.1.X2 Change of Value Notification from Life Safety Objects Test  
BTL Test Plan-5.0.final

### **Background:**

BTL Test Plan-5.0.final section 4.9.7 in both 9.2.1.X2 Change of Value Notification from Life Safety Objects and BTL - 9.3.X5 Change of Value Notification from Life Safety Objects have Test Conditionality: Either 9.2.1.X1 or 9.3.X5 must be executed.

### **Question:**

Should BTL Test Plan-5.0.final instead say: Test Conditionality: Either 9.2.1.X2 or 9.3.X5 must be executed.

### **Response:**

Yes.