

Clarification Request

References: BTL Test Plan 5.0, BTL Specified Tests

Date of BTL-WG Response: __21-Jul-2011 and 04-Aug-2011__

Tests 8.2.1, and 8.3.1 test analog objects for correct COV notification behaviour. In steps 8 through 10, the tests require that the object be changed by an amount less than the COV increment.

In objects that have a fixed COV_Increment that is equal to the smallest change that the object supports, these steps cannot be executed.

Question:

Should the test be modified to allow for the testing of objects where any change will result in a COV notification?

Response:

Yes. If an object has a fixed COV_Increment that is equal to the smallest change that the object supports, then the steps 8 through 10 shall be skipped. An SSPC proposal will be made by the BTL Manager, for an addendum that will yield clarification within the standard itself regarding an the internal resolution to avoid continual COVNotification when hovering right at the threshold.