

Clarification Request

References: BTL Test Plan 14.0.final, 135.1-2013 Test 8.18.3 AE-ELV-A

Date of BTL-WG Response: March 19, 2015

☒ All actions necessitated have been completed

Background:

5.12 Alarm and Event - Event Log View - A

135.1-2013 - 8.18.3 - Reading and Presenting Properties		
	Test Method	Manual
	Configuration	As per <i>ASHRAE 135.1-2013</i> .
	Test Conditionality	Must be executed
	Test Directives	Repeat the test for each of the properties listed in the table in the BIBB definition.
	Testing Hints	
	Notes & Results	

The referenced table in the BIBB definition of AE-ELV-A does not exist in the Standard 135-2012

Question:

Should I use the table of the BIBB AE-ELVM-A?

Response:

No. Use the text in the BIBB to determine the properties required. The BTL-WG will update the language in the BTL Test Plan.