

Clarification Request

References: BTL Specified Tests 15.0.final - 7.2.X1 - Date Pattern Properties Test

Date of BTL-WG Response: 2018-Apr-15

☒ All Actions Necessitated have been Completed

Background: BTL Specified Tests 15.0 - 7.2.X1 - Date Pattern Properties Test

Test Conditionality: Must be executed.

Test Directives: Apply to the Exception_Schedule property.

Problem:

Devices may be restricted and do not permit writing to Exception_Schedule property. In that case the test cannot be executed.

Question:

Is it allowed to skip the test if the Exception_Schedule property is not writable?

Response:

Yes. This change exists in Add-BTL Test Package 15.0-a and will be part of Test Package 15.1.