

Clarification Request

References: BTL Test Plan 12.0.final, 135.1-2009, AE-INFO-B, 135.1-2009-9.8.5

Date of BTL-WG Response: 04/18/2017

Background:

The BACnet standard allows a device to implement AE-N-I-B without implementing AE-ACK-B as long as no notifications will be generated with the 'Ack Required' parameter set to TRUE (and by extrapolation that no event-generating objects will have an Acked_Transitions property with a value other than (T, T, T)).

BIBB AE-N-I-B requires support for AE-INFO-B.

In the BTL Test Plan, support for AE-INFO-B requires application of test 9.8.5 which requires that an object in the IUT be configured with the Acked_Transitions property set to a value other than (T,T,T).

Question:

Is this test allowed to be skipped when the IUT does not support AE-ACK-B?

Response:

Yes, this test is allowed to be skipped.