

### Clarification Request

**References:** BTL Test Plan 20.0.1 chapter 8.13.2 test 8.24.3 / 8.24.6 / 8.24.7

**Date of BTL-WG Response:** September 22, 2022

**Background:** BTL Specified Tests-20.0.1 final tests 8.24.3 and 8.24.6 and 8.24.2

1. RECEIVE DeviceCommunicationControl-Request,  
'Time Duration' = (any unsigned value > 0),  
'Enable/Disable' = ~~DISABLE~~, *DISABLE-INITIATION*  
'Password' = (a password of at least 5 characters) (a password of up to 20 characters)
2. TRANSMIT BACnet-SimpleACK-PDU

(Test 8.24.6 is similar to 8.24.3 but without password.)

(Test 8.24.2 is similar to 8.24.3 but with a password up to 20 characters)

**Problem:**

All three tests are requesting the deprecated value **DISABLE** for the 'Enable/Disable' parameter.

**Question:**

1. Shall the tests be altered to a valid value for 'Enable/Disable' parameter?
2. Is it allowed that a Rev\_22 IUT (B-AWS) does not support the deprecated value **DISABLE**?

**Response:**

1. Yes.
2. Yes.