

## **Clarification Request**

**References:** ASHRAE 135.1-2007

### **Background**

Test **135.1 – 2007 7.2.2.1 Read-only Property Test** presumes that the alternative rules during Out\_Of\_Service are not in effect.

### **Question:**

Should this test configure Out\_of\_Service to FALSE? Be conditional for objects for which Out\_Of\_Service is in effect by default? Be acceptable if some but not all objects of the same type can configure Out\_of\_Service to FALSE?

### **Response:**

The correct spirit of the test does not require Out\_Of\_Service to be false. We will hereafter ask vendors to submit an EPICS that matches the device we have in hand for test, with writability as exhibited by the device in that condition.