

Clarification Request

Reference: "BTL Implementers Guide-17", "BTL Checklist-3.0.final", "ASHRAE 135.1-2003"

Background:

The property 'protocol-conformance-class' was deleted in protocol revision 2.

Question:

If a device supports a protocol revision of 2 or greater, should this property be required to be deleted (missing) from the device implementation?

Response:

Yes.