

Clarification Request

Reference: "BTL Specified Tests-3.0.final", "ASHRAE 135.1-2003"

Background:

Consider the situation where the IUT sends a Confirmed Event Notification to a device that does not respond with an acknowledgement. The IUT will then repeat the request the number of APDU Retries.

If the request is still not acknowledged, is it appropriate for the IUT to send another set of Confirmed Event Notifications containing the same information by changing the invoke_id?

Response:

The BTL working group agrees that this is acceptable but is not a required action.