

### **Clarification Request**

**References:** BTL Test Plan 12.0

**Date of BTL-WG Response:** June 20, 2013

**Background:**

**5.5.1 - 9.1.1.X3 Successful Alarm Acknowledgment of Confirmed Event Notifications when 'To State' is either High-Limit or Low-Limit, Revision 5 and higher only**

**the conditionality for this section is “must be executed”.**

**Question:**

Should the conditionality allow to skip the test if the IUT does not support any High-Limit or Low-Limit states?

**Response:**

**Yes.**