

Clarification Request

References: [BTL Specified Tests-5.0.final](#)

Background / Proposed Solution:

Is a vendor instruction to configure the B/IP of IUT with a subnet mask of 255.255.0.0 permitted in BTL Specified Test 14.7.3.2?

Response:

No, if it doesn't support allowing the tester to alternately set the subnet mask to 255.255.255.0 or any other valid value. A device must support any legal IP address to claim datalink layer BACnet/IP.