

### Clarification Request

**References:** 9.2.2.1, 9.2.2.2, 9.2.2.4 negative tests for DS-COV-A

**Date of BTL-WG Response:** \_\_25-May-2017\_\_

☒ All actions necessitated have been completed

#### Background:

BTL-CR-0407 clarified that of the required COVNotification services only at least one is required.

#### Problem:

A device that supports only executing UnconfirmedCOVNotification will not need to perform the negative tests, since there are no responses for UnconfirmedCOVNotification execution. Test Plan section 4.9.1 on the negative tests for DS-COV-A need a Test Conditionality that these have to be executed only if the device supports ConfirmedCOVNotification.

#### Question:

Is it correct to change the **Test Conditionality** from **Must be executed.** to **Must be executed if the device supports ConfirmedCOVNotification execution** for these three tests.^

135.1-2013 - 9.2.2.1 - Change of Value Notification Arrives after Subscription has Expired		
	Test Method	
	Configuration	As per <i>ASHRAE 135.1-2013</i> .
	Test Conditionality	Must be executed.
	Test Directives	
	Testing Hints	
	Notes & Results	
135.1-2013 - 9.2.2.2 - Change of Value Notifications with Invalid Process Identifier		
	Test Method	
	Configuration	As per <i>ASHRAE 135.1-2013</i> .
	Test Conditionality	Must be executed.
	Test Directives	
	Testing Hints	
	Notes & Results	
135.1-2013 - 9.2.2.4 - Change of Value Notifications with Invalid Monitored Object Identifier		
	Test Method	
	Configuration	As per <i>ASHRAE 135.1-2013</i> .
	Test	Must be executed.

	<b>Conditionality</b>	
	<b>Test Directives</b>	
	<b>Testing Hints</b>	
	<b>Notes &amp; Results</b>	

**Response:**

**No. However, these tests will be moved to section 4.9.3 in the Test Plan. Therefore, they do not need to be executed for devices that do not subscribe for confirmed notification.**