

Clarification Request

References: BTL Test Plan 9.0.final

Date of BTL-WG Response: Nov 27, 2012

Background:

in chapter 4.12 Data Sharing - Advanced View -A test 8.18.3 - Reading and Presenting Properties

Testing Hints:

Repeat the test for all standard objects and properties, excluding the Life Safety and Access Control objects, and the Object_Identifier and Object_Type properties.

Questions:

1. How do we recognize an “Access Control object”?
2. Does the “Credential Data Input Object” count as an “Access Control object”, that does not need be presented for the BIBB DS-AV-A?

Response:

The Access Control objects are those defined in 135-2008j and 135-2004f. The answer to question 2 is yes.