

## Clarification Request

**References:** “e.g” Work-Item #423, DS-COV-B, Proposed for test package 16.0

**Date of BTL-WG Response:** 13-Dec-2018

☒ All Actions Necessitated have been Completed

**Background:** “e.g” Test Directive of tests BTL 9.11.1.X11 and X12 too harsh.

TODO - Paste entire existing test here, then, use ~~striethrough for parts of test to be stricken~~  
and *italics for new material*. **Then highlight in yellow, all parts you have changed.**

### Problem:

The test directive of the tests 9.11.1.X11 and X12 require to repeat the test for all properties which support SubscribeCOVProperty. Our understanding of this directive is to test all instances of such properties even supporting the same data-type which easily ends up in several hundred test instances.

This does not make any sense and from our perspective it doesn't provide any benefit or added value.

The suggested work item #423 already contains a checklist item for each of the supported data-types, so the testing scope will remain identical without the need to test several instances of properties having the same data-type.

### Question:

**Wouldn't it make much more sense to modify the test directive of the two tests as follows (and as already present in tests 9.11.1.X21 and 22):**

**Repeat test for at least one object of each type that has at least one property which supports SubscribeCOVProperty. ~~repeat test for all Properties which support SubscribeCOVProperty.~~**

### Response:

**Yes. The test plan test directives will be modified.**

**The test should be run for each data type and each object type.**