

Clarification Request

Reference: "BTL Specified Tests 3.0.final", "ASHRAE 135 2004"

Background:

In several of the Acknowledge Alarm Service tests in the BTL Specified Tests document, there appears to be a requirement that when the Ack_Required property is set to TRUE that the Notify_Type property must be set to ALARM.

The ASHRAE 135 2004 does not have this restriction.

Question:

Is this an implied requirement or should the tests be modified to have EVENT | ALARM for their Notify_Type?

Response:

Yes. The BTL will modify the tests that are affected.