

Clarification Request

References: ASHRAE 135.1-2003

Background / Proposed Solution:

Test **9.8.3 Event Information with Multiple Active Events** states that "This test shall be executed only for devices that contain more than one object that can detect alarms." However, Test **9.8.6 Chaining Test** does not make that statement, implying that the test **9.8.6** is always required even if only one object can detect alarms.

Question:

Since in order for test **9.8.6** to be performed, more than one object must be able to detect alarms should the statement "This test shall be executed only for devices that contain more than one object that can detect alarms" be added to the Test **9.8.6 Chaining Test**?

Response:

Yes. This issue has been addressed in proposal LJT-001.