

## **Clarification Request**

**References:** ["BTL Test Plan-5.0.final", "ASHRAE 135.1-2007", "BTL Specified Tests-5.0.final"]

### **Background / Proposed Solution:**

"BTL Test Plan-5.0.final" chapter 8.8.1 references test 9.30.1.1 - Local Broadcast from 135.1-2007. A modified version of that test does exist though in the BTL specified test. The modified test specifically takes into account that the optional property utc-offset might not be present in the IUT.

### **Question:**

Should BTL Testplan 5.0 refer to test 9.30.1.1 from BTL specified tests instead of the original test from 135.1-2007?

### **Response:**

Yes.