

## Clarification Request

**References:** BTL Test Plan 9.0.final Test Conditionality on 9.8.5

**Date of BTL-WG Response:** Nov 13, 2012

### Background:

#### Test Plan 12.0 section 5.15.1 test 9.8.5

Test 9.8.5 for AE-INFO-B in test plan has conditionality "Must be executed". If the IUT does not support AE-ACK-B, however, or at least have the ability such that at least one Acked\_Transition property can contain a value other than (T,T,T) then this test cannot be executed.

"Supports AE-ACK-B" in the AE-N-I-B section in the Checklist has footnote 1 stating: Required if EventNotifications with service parameter AckRequired = True can be issued. In practical terms, an EventNotification with service parameter AckRequired = True being issued is the only way an Acked\_Transition property can be made to contain a value other than (T,T,T).

Test 9.8.5 deserves conditionality language at least equal to that footnote.

### Question:

Should the conditionality be "if IUT supports AE-ACK-B" instead?

### Response:

Yes, that phrase will be appended.