

## Clarification Request

**References:** ASHRAE 135.1-2023, ASHRAE 135-2024, Test Package 26.0.

**Date of BTL-WG Response:** July 10, 2025

**Background:**

---

### 4.15 Initiates ReadRange

---

#### 4.15.1 Base Requirements

Base requirements must be met by any IUT that initiates ReadRange.

135.1-2023 - 8.21.1 - Reading Values with no Specified Range, or 135.1-2023 - 8.21.3 - Reading a Range of Values by Position		
	Test Conditionality	May be skipped if the IUT initiates ReadRange in another tested BIBB that uses ReadRange (eg T-ATR-A).
	Test Directives	
	Testing Hints	

**Problem:**

If the IUT support ReadRange by Sequence Number or by Time only, these tests can be skipped.

The Test Conditionality allows these tests to be attempted if the IUT does not support ReadRange with no range or by position.

**Question:**

1. If ReadRange with no range is not supported, should 8.21.1 be skipped?
2. If ReadRange by Position is not supported, should 8.21.3 be skipped?

**Response:**

**1. Yes**

**2. Yes**