

Clarification Request

Request from: BTL Manager <btl-manager@bacnetinternational.org>

References: BTL Functionality Checklist, at least one data-link layer

Stage: ☒Request, ☐Listed, ☐Analysis, ☒Resolved

Background / Proposed Solution:

The BTL Checklist contains no conditionality indication that at least one data-link layer Base Requirements lineitem shall be selected.

	R ¹	Base Requirements
<i>¹At least one of the Data-Link Layer or BACnet/IP – Annex J Base Requirements shall be selected.</i>		

Question:

Should the BTL Checklist add mention that at least one data-link layer Base Requirements lineitem shall be selected? Should the test lab simply enforce that?

Response:

No change is needed. The BTL Checklist will not be modified. Test lab managers shall ensure that at least one data-link layer is specified.