

Clarification Request

References: BTL Specified Tests 7.3.2.23.X1.3

Date of BTL-WG Response: __21-Apr-2011__

Background / Proposed Solution:

Section “Supports Writable List_Of_Object_Property_Reference Property” mentions that this property should be writable but is not clear that it should be writable with any property identifier.

Test configuration for **7.3.2.23.X1.3 Externally Written Data types Test, non-NULL values**

says that at least one property of required data type should be configurable to test this case.

SCHED-E-B also depends on DS-WP-A as both are interlinked. Yet checklist doesn't mandate that Boolean data type be writable by DS-WP-A to support it.

Question:

We are supporting writing Boolean Data Type only through Scheduling – External – B and only for the Trend Log Object and only for the Enable property.

We would like to confirm that this implementation is fine. Is it acceptable?

Response:

No. SCHED-E-B requires scheduling capability for any standard property in any standard object, up to the Protocol_Revision claimed, for all the datatypes that are required by the BIBB.