

Clarification Request

References: ASHRAE 135.1-2007, BTL Specified Tests-5.0.final

Background

Test **BTL 9.33.2.3 corrected test 135.1 – 2007 9.33.2.3:**

Test Plan 5.0.final section 8.2.1 includes

135.1-2007 - 9.33.2.3 - General Inquiry, Directed to a Remote Device

Question:

Is this an errata?

Response:

The Test Plan is incorrect and should refer to BTL - 9.33.2.3