

Clarification Request

References: BTL_Testing_Policies-15.1.fi

Date of BTL-WG Response: 15-Mar-2018

Background:

Recently BTL Testing Policies has been updated. Changes are made in section 2.2 which are mentioned below:

The BTL Testing process requires that applicants completely and accurately complete the BTL Functionality Checklist. The checklist is not the set of functionality that the applicant wants tested; it is the set of functionality implemented in the device.

All functionality implemented in the product shall be claimed in the checklist, including partial implementations.

Problem:

Lab has received application where the bits for GetAlarmSummary and GetEnrollmentSummary are True, in Protocol-Services-Supported property of Device object. However, the claim for their respective BIBBS (AE-ASUM-B, AE-ESUM-B) are not marked in Functionality Checklist.

Both the BIBBS AE-ASUM-B, AE-ESUM-B are now deprecated as per **ANSI/ASHRAE Standard 135-2016**.

As per the updated testing policy, we feel that the BIBBS should be claimed in the Functionality Checklist, as they are implemented in the product.

Questions:

1. Is the testing policy applicable for the BIBBS that are deprecated as per the latest standard?
2. Should we ask applicants to add those BIBBS in Functionality checklist?

Response:

- 1) Yes.
- 2) Yes.